



ADDENDUM #2

PAINT UPGRADE PROJECT

BID #FY24012

May 1, 2024

Time and Date Due: 11:00 A.M., Central Time, **Tuesday, May 7, 2024**

Location: Bids are due no later than 11:00 A.M., Central Time, Tuesday, May 7, 2024, in Purchasing Services, Bartlett City Schools Administration Offices, 5705 Stage Road, Bartlett, Tennessee 38134. All bids must be time stamped in Purchasing Services, Bartlett City Schools Administration Offices, 5705 Stage Road, Bartlett, Tennessee, 38134, prior to 11:00 A.M., Central Time, Tuesday, May 7, 2024. All bidders will meet in the lobby of Bartlett City Schools Administration Offices, 5705 Stage Road, Bartlett, Tennessee 38134 prior to 11:00 A.M., Central Time, Tuesday, May 7, 2024, and move to the Conference Room for the bid opening.

Number of Pages of Addendum #2 – 2 (two) Signed addendum must be acknowledged and included with your response to Bid #FY24012. All sheets included in Addendum #2- Bid #FY24012 must be included with your bid response.

Failure to sign, acknowledge and include any and all addendums may result in your response being disqualified and rejected. Names and signatures below certify that you acknowledge, understand, and agree to all information in Addendum #2- Bid #FY24012.

Authorized Representative (Print)

Signature

Date

Questions/Responses

Bon Lin Elementary:

1. Spec Section 071900 states water repellants to be applied to exterior and interior; however, drawings only state exterior – please verify. **Exterior only**
2. Please provide exterior drawings/views if there is any outside painting. **No exterior painting**
3. Sheet A1.4 – need count of existing trees and mascots in corridors. **What is shown in the drawings are the only ones we are painting over. Otherwise, field verify.**
4. Sheet A7.1 states yellow & red wainscot to remain – please confirm that this will not require repainting or touch up. **As noted under the 'Finish Notes' #13 states existing paint in renovated areas to receive a new coat of paint. You must match existing colors per school. This includes all corridor colors. Field verify colors per school since corridors have their own color.**

Appling Middle:

1. Sheet A7.1 – will cloth canopy be removed & replaced by owner? **No, you will be responsible for removing them and placing them back. Coordinate with owner where to store on site.**

ALL Schools:

1. Can you please provide detail of owner supplied graphic for “Home of ...” showing letter sizes/fonts? **Refer to Addendum #1**
2. Please provide ceiling drawings of all 3 schools so we can locate the gypsum ceilings and/or furr downs that need to paint. **Field verify**
3. Can you please provide a count of painted mascots in the gym in each school and/or provide photos of gym elevations showing painted graphics. **Painted mascots are excluded in the scope. Noted on plans there will be a cap at each one. field verify all graphics locations. If existing graphics are damaged during the new painting job, you will be responsible for repairing it as new.**
4. Can you please provide the ceiling height of the cafeteria and gym of each school. **Estimated height Gym – 25'-0" and Cafeteria 14'-0". Shall not be used for take-offs. Field verify exact heights.**
5. Will owner applied and/or installed art/misc. items be removed by owner? **If this refers to posters and paper graphics in the corridors, the school will remove these items before summer. If not, please clarify your question.**